House:	Year:	

MONTHLY FLOWING WATER TEMPERATURE CHART

MINIMUM 40° CELSIUS 104° FAHRENHEIT MAXIMUM 49° CELSIUS 120° FAHRENHEIT

TO BE COMPLETED THE FIRST WEDNESDAY OF EVERY MONTH PRIOR TO 11:30 A.M.

	Tap Location	Temperature	Initial	If Applicable, Back-up Temperature	Initial
JAN					
FEB					
MAR					
APR					
MAY					
JUN					
JUL					
AUG					
SEP					
ОСТ					
NOV					
DEC					

Binder(s):	Adult Services					Page:	1 of 2
Section(s):	Health & Safety	A	Mar 7/12	R/R	Mar 19/14	R/R	Mar 3/15
Program Area(s):	Adult Disability	R	Oct 1/18				

WORK INSTRUCTIONS

- Acceptable temperature range: 40° to 49° (104° to 120° F)
- To be completed on the 1st Wednesday of every month before
 11:30 AM (this allows for immediate follow-up if required)
- Select a different tap in the home each month to be tested (except therapeutic tubs)
- Turn tap to the hottest setting for at least 1 minute
- Hold thermometer under running water for at least 1 minute and until the thermometer scale stops rising
- If the temperature is within acceptable range (40° to 49°) record and initial the correct boxes on the form
- If temperature <u>is not</u> within acceptable range, repeat test with backup thermometer
- If temperature <u>is</u> within acceptable range with the backup, discard the 1st thermometer and request a new one from ASC Admin
- If temperature <u>is not</u> within acceptable range after using the backup, notify ASC admin and supervisor immediately so that follow up can be completed. A Safety and Maintenance Form must be completed and forwarded to Manager

Binder(s):	Adult Services					Page:	2 of 2
Section(s):	Health & Safety	A	Mar 7/12	R/R	Mar 19/14	R/R	Mar 3/15
Program Area(s):	Adult Disability	R	Oct 1/18				